

ANSI/ISO SYMBOL	ANSI/ISO CODE	IEC SYMBOL	IEC CODE	DESCRIPTION
	CB		QF	CIRCUIT BREAKER
	CON		KM	NC RELAY
	CON		KM	NO RELAY
	CR		KA	RELAY COIL
	PL		XS	PLUG
	FU		FU	FUSE
	MOV		VAR	METAL OXIDE VARISTOR
	CF		M	CIRCULATION FAN
	T		X1	TERMINAL
	GND		GRD	GROUND
	FS		FLS	FLOW SWITCH
	SV		YV	SOLENOID

ANSI/ISO SYMBOL	ANSI/ISO CODE	IEC SYMBOL	IEC CODE	DESCRIPTION
	PB		SB	PUSH BUTTON (NO)
	PB		SB	PUSH BUTTON (NC)
	PB		SB	MUSHROOM HEAD (NO)
	PB		SB	MUSHROOM HEAD (NC)
	PS		SP	PRESSURE SWITCH
	TS		ST	TEMPERATURE SWITCH (NC)
	TS		ST	TEMPERATURE SWITCH (NO)
	SS		SA	SELECTOR SWITCH (NC)
	SS		SA	2 POSITION SWITCH (NO)
	SS		SA	3 POS SELECTOR SWITCH (NC)
	SS		SA	3 POS SELECTOR SWITCH (NO)
	SS		SA	3 POS SELECTOR NR SWITCH (NO)
	LS		SQ	LIMIT SWITCH (NC)
	LS		SQ	LIMIT SWITCH (NO)

ANSI/ISO SYMBOL	ANSI/ISO CODE	IEC SYMBOL	IEC CODE	DESCRIPTION
	PX		PRX	PROX SWITCH 2 WIRE (NC)
	PX		PRX	PROX SWITCH 2 WIRE (NO)
	PX		PRX	PROX SWITCH 3 WIRE (NO)
	PC		PEC	PHOTO CELL
			T	TRANSFORMER
	JMP			JUMPER
	WH		AH	WARNING HORN
	LT		HL	INDICATOR LIGHT
	WB			BEACON
	PWS			POWER SUPPLY

ELECTRICAL SYMBOLS

REV.	ZONE	CHANGE DESCRIPTION	DATE	CHANGE BY
*	*	*	*	*
*	*	*	*	*
*	*	*	*	*

INSTALL MOTOR OVERLOAD HEATERS PER MOTOR NAMEPLATE SPECIFICATIONS. THIS EQUIPMENT IS TO BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE AND LOCAL CODES AND ORDINANCES. INSTALLATION IS TO BE PERFORMED BY A LICENSED ELECTRICIAN AND INSPECTED BY LOCAL AUTHORITIES. PLEASE DISCONNECT ALL POWER BEFORE SERVICING.

THIS DRAWING AND ITS PRINCIPLES OF DESIGN CONTAINS PROPRIETARY AND CONFIDENTIAL INFORMATION OF COLUMBIA MACHINE, INC. DESIGN NOT TO BE USED, COPIED OR DISCLOSED WITHOUT WRITTEN PERMISSION. PROTECTED UNDER U.S. AND FOREIGN COPYRIGHT LAW. ALL RIGHTS RESERVED.

Columbia
COLUMBIA MACHINE INC.
VANCOUVER, WA 98661
CONCRETE PRODUCTS
DIVISION

61249 NEWFOUNDLAND & LABRADOR ST. ST. JOHN'S, NEWFOUNDLAND
DRAWN BY: PERMIT DAVENUS
CHECKED BY: JAMES
GIBBER: JAMES
ET: JAMES
REF: ONE
ONE

INFORMATION ONLY

SYMBOL SCHEDULE

SIZE DWG NO: **328.161.284.1**

REV. SHEET: **4 OF 44**